
# lightnet

Lightnet GmbH Zollstockgürtel 65 50969 Köln / Germany Tel.: +49 (0) 221 22 25 26-0 E-Mail: info@lightnet.de www.lightnet.de


## MATRIC GX/RX | SYSTEM 40MM SUSPENDED


#### 1. MONTAGE UND INSTALLATION | MOUNTING AND INSTALLATION:





L1[mm] = L[mm] - 40mm	
Opal / Microprismatic / Wallwasher	Lens Louver
L[mm]	L[mm]
890	930
1182	1194
1475	1458
1765	1723
2055	1987

Montageöffnungen.
Installation openings.












cut off the excess of the suspension cord or roll it up and secure it to avoid a short-circuit caused by contact with the light sources.








# lightnet

Lightnet GmbH Zollstockgürtel 65 50969 Köln / Germany Tel.: +49 (0) 221 22 25 26-0 E-Mail: info@lightnet.de www.lightnet.de

### MATRIC GX/RX | SYSTEM 40MM SUSPENDED



#### IMPORTANT:

-all sections must be suspended individually and perfectly levelled (horizontally and vertically) before connecting them together - this is crucial

-all suspension cords must be positioned perfectly vertical

-all suspension cords must be tensioned with the same strength

-if these conditions are not satisfied then the different parts will settle to different levels and work against one another.

11. Maximum current load allowed to through-wiring is 13A. Non-user replaceable light source.